



Inspection Certificate

Project: **unknown**

Client: **Hauff-Technik GmbH & Co. KG
Robert-Bosch-Strasse 9
D-89568 Hermaringen/Germany**

Office: **Dortmund**

Clients Order Number: **N/A**

Date: **09 June 2015**

Order Status: **N/A**

Inspection Dates

First: **09 June 2015**

Final: **09 June 2015**

This certificate is issued to **Hauff-Technik GmbH & Co. KG, Hermaringen/Germany** to certify that the undersigned surveyor did, at their request, attend at their works on the date shown above for the purpose of examining the below equipment:

Description of Goods / Services:

1 (ONE) pc. Modular Seal

Seal type: 11 x GKD 325
Consisting of: Elastomer segment GKD 325 EPDM 50±5 Shore
Upper press plate GKD 325 PA 6.6 GF 35
Press plate with nut GKD 325 PA 6.6 GF 35 AISI 316 L
Assembly indicator
Bolt DIN 912, M8x110/55, AISI 316 L

Scope of inspection:

Witness of pneumatic pressure test, test pressure 5 bar g, >72 hours, test medium air, ambient temperature 22 °C

As far as could be verified, all used measuring equipment was duly calibrated and the scope of inspection as listed above has been closed with satisfactory results.

Remark:

No hard stamp has been applied by Lloyd's Register



R. Potzel
Surveyor to Lloyd's Register EMEA

A subsidiary of Lloyd's Register Group Limited

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.