


Fire protection kit S90

for HSI150 press seal

HSS150 HSI150 HRD

Article no.: 5030010031, GTIN: 4052487233583



• Special assembly pockets for the assembly of pads on one side

Gastight and watertight fire barrier meeting the requirements of fire resistance class S90 in accordance with DIN 4102-9 for installation in the HSI150 system for walls. The seal is created with the HRD press seal. The barrier is approved for use with all types of cable in walls.



Picture may differ from selected product

FACTS

Advantages:

- Fire protection for HSI150 cable entry
- No additional wall attachments necessary
- No limits on individual cable diameters
- Weatherproof fire-stop pads
- Approval for packages with HSI 150 up to 2 x 6

Scope of delivery:

- 1 set of HVS pads for full assignment (without cable): 2x HVS-K-400, 3x HVS-K-250, 3x HVS-KB-60
- Stainless steel clamping strap
- 1 piece Identification sign

Dimensions:

- Wall thickness at and above: 150 mm
- Barrier thickness: min. 280 mm
- Maximum package size: 430 x 1270 mm (2x6)

Tests/Standards:

• DIBT approval Z-19.15-1906 to DIN 4102-9

FEATURES

Wall sleeve/core drilled hole ID (mm):

150

ACCESSORIES REQUIRED







Flexible socket wrench



Assembly plate for fire-stop pads